

DESCRIPTION	QTY
MEDIUM BODY SEALING GLAND	x1
MEDIUM NUT	x1
O-RING BS124 NITRILE	x2
STRENGTH MEMBER RETENTION BRACKET	x1
8-WAY CIRCULAR GRIP PLAT	x1
M4 x 12mm CSK POZI PAN SCREW	x1
8-WAY CIRCULAR CABLE SEAL	x1
8-WAY SPACER	x1
8-WAY SEAL PIN	x1
8-WAY CIRCULAR x8 BLANKS ON SPRUE	x1
1mm SPACER	x3
ARAMID RETENTION BACKET	x1
ARAMIID RETENTION CLIP	x4
GREASE SACHET	x1
14 9 6 13	1 3 2 11
	MEDIUM BODY SEALING GLAND MEDIUM NUT O-RING BS124 NITRILE STRENGTH MEMBER RETENTION BRACKET 8-WAY CIRCULAR GRIP PLAT M4 x 12mm CSK POZI PAN SCREW 8-WAY CIRCULAR CABLE SEAL 8-WAY SPACER 8-WAY SEAL PIN 8-WAY CIRCULAR x8 BLANKS ON SPRUE 1mm SPACER ARAMID RETENTION BACKET ARAMIID RETENTION CLIP GREASE SACHET




#### Step 1

REMOVE PORT BLANK FROM BASE BY FULLY SQUEEZING TOGETHER THE TABS FROM INSIDE THE BASE.

NOTE: YOU MAY NEED TO ROTATE THE BLANK IN THE PORT TO SQUEEZE THE TABS.

USING YOUR OTHER HAND OR PLIERS, HOLD THE CENTRAL RIB AND FIRMLY PULL UNTIL THE PORT BLANK IS RELEASED.



**Page 2 of 17** 



Step	2

IDENTIFY THE CABLE DIAMETER AND USING THE TABLE BELOW SELECT THE CORRECT NUMBER OF SPACERS REQUIRED.

CABLE 🔊	SEAL SIZE (9)	CABLE RANGE	SPACERS (11)
2.4mm	SEAL	2.4-2.6mm	2
3.0mm	XJTSG02139	3.0mm	3



### Step 3

INSERT THE SEAL PIN (9) INTO THE CENTRAL HOLE OF THE SEAL (7), THEN INSERT THE ASSEMBLY INTO THE GLAND ASSEMBLY (1) AS SHOWN.



**Page 4 of 17** 




#### Step 4

THREAD THE SPACERS (11) IF REQUIRED, 8-WAY SPACER (8) AND MEDIUM NUT (2) ONTO THE CABLE. APPLY SILICON GREASE (14) TO THE CABLE/TUBE AND PUSH THE CABLE/TUBE THROUGH ONE OF THE HOLES IN THE CABLE SEAL (7). BEFORE LOOSELY FITTING MEDIUM NUT (2) ONTO MEDIUM BODY (1) APPLY SILICON GREASE (14) ONTO INSIDE THREADED AREA.

GO TO STEP 5 FOR BEND LIMITING TUBE INSTALLATION.

GO TO STEP 8 FOR 2.4mm & 3.0mm CABLE INSTALLATION.



**Page 5 of 17** 




#### Step 5

LOCATE THE BEND LIMITING TUBE.

BE CAREFUL TO ENSURE ALL THE EDGES HAVE BEEN REMOVED SO THE BEND LIMITING TUBE IS SMOOTH READY TO BE PUSHED THROUGH THE SEAL.

FIRMLY PUSH THROUGH THE BREAK-OUT LAYER, FEED THE TUBE THROUGH UNTIL THE TUBE PASSES THE GRIP PLATE XXmm, AS BELOW. LOOSELY SCREW ON THE MEDIUM NUT (2).

**NOTE:** ENSURE THE CABLE SLOT OF THE SEAL (7) AND SPACER (8) LINE UP BEFORE INSERTING CABLE.






#### Step 6

LINE THE TUBE UP WITH THE NEAREST CABLE GRIP POSITION IN THE 8-WAY GRIP PLATE (5). PUSH THE CABLE INTO THE GRIP TO SECURE. LIGHTLY PULL ON THE CABLE TO TEST THE CABLE HAS BEEN PUSHED IN FULLY.

NOTE: LOCATE THE GROOVE OF THE TUBE INTO THE GRIP PLATE SLOT.






Step 7

REPEAT STEP 4 TO 5 AS MANY TIMES AS NECESSARY TO ADD ALL ADDITIONAL TUBES REQUIRED. REMOVE ENOUGH BLANKS FROM THE SPRUE (10) TO POPULATE ALL REMAINIG CABLE SLOTS. ENSURE BLANK IS INSERTED CORRECTLY, IT HAS THE SAME PROFILE AS CABLE.

GO TO STEP 12.






#### Step 8

REMOVE STRENGTH MEMBER RETENTION BRACKET (4) AND REPLACE WITH ARAMID RENTENTION BRACKET (12).

PUSH THROUGH APPROX 2.2m OF 2.4mm OR 3.0mm DIAMETER CABLE INTO THE SEAL. FIRMLY PUSH THROUGH THE BREAK-OUT LAYER, LOOSELY SCREW ON THE MEDIUM NUT (2).

NOTE: ENSURE THE CABLE SLOT OF THE SEAL (7) AND SPACER (8) LINE UP BEFORE INSERTING CABLE.




**Page 9 of 17** 



#### Step 9

STRIP CABLE BACK 2m (CMJ, MMJ) or 3m (LMJ) EXPOSING THE ELEMENTS, GRP AND ARAMID YARN IF APPLICABLE.

MEASURE FROM THE CABLE BUTT AND CUT THE ARAMID YARN TO 170mm. APPLY GREASE (14) ALONG CABLE SHEATH FROM THE BUTT BACK 200mm & PULL CABLE BACK UNTIL BUTT ENDS UP IN POSITION SHOWN.



Page 10 of 17


# Prysmian Group INSTALLATION INSTRUCTION

### MECH SEAL – 8-WAY 2.4mm & 3.0mm CABLE INSTALLATION GUIDE

#### Step 10

SEPARATE THE ARAMID FROM THE FIBRES ENSURING IT IS GATHERED IN ONE DIRECTION AND NOW SQUEEZING THE FIBRES.

TEMPORARILY TUCK THE LOOSE FIBRE OUT OF THE WAY (BEHIND THE NEAREST ARAMID CHANNEL).



WHILST KEEPING TENSION ON THE CABLE, BEGIN TO WRAP THE ARAMID AROUND THE ARAMID CHANNEL STARTING FROM THE INSIDE TO OUTSIDE UNTIL A MINIMUM OF 1.5 TO 2 TURNS HAVE BEEN MADE.

NOTE: EACH ARAMID CHANNEL CAN HOLD 2 CABLES WORTH OF ARAMID.




#### Step 11

WHILST KEEPING TENSION ON THE ARAMID, SLIDE THE ARAMID RENTION CLIP (13) INTO PLACE. IT SHOULD FEEL FIRM TO SLIDE ON. IS IT DOESN'T REMOVE THE CLIP AND MAKE ANOTHER TURN OF ARAMID AROUND THE ARAMID CHANNEL.

TRIM THE REMAINING ARAMID TAIL LEAVING 10mm MINIMUM.


REPEAT STEP 8 TO 11 AS MANY TIMES AS NECESSARY TO ADD ALL ADDITIONAL 2.4mm OR 3.0mm CABLES REQUIRED.





### Step 12

FINALLY TIGHTEN THE MEDIUM NUT (2) DOWN TO THE BASE OF THE THREAD.



Page 13 of 17



#### Step 13


PUSH GLAND (1) INTO CMJ BASE. ONCE RESISTANCE ON O-RING IS FELT, CONTINUE PUSHING WITH A TWISTING ACTION UNTIL AN AUDIBLE CLICK IS HEARD. VISIUALLY CHECK FROM INSIDE THE BASE ALL 3 CLIPS ARE SECURED INTO BASE.





Step 14

INSERT THE FLAT DROP CABLE INTO THE MANIFOLD RESTRAINT AND ENSURE THE SHEATH ALIGNS AT THE INDICATED POSITION, AS SHOWN. ROUTE ELEMENTS AND FIBRES AS PER THE CLOSURE INSTALLATION INSTRUCTIONS.



Page 15 of 17



Step 15

#### **ADDITIONAL CABLE INSTALLTION**

TO INSTALL ADDITIONAL CABLES, LOOSEN THE MEDIUM NUT (2) AND REMOVE NUMBER OF BLANKS (10) REQUIRED TO NEW INSTALL NEW BEND LIMITING TUBE/2.4mm OR 3.0mm CABLES.



Page 16 of 17



Step 16			
ADDITIONAL CABLE INSTALLTION			
<b>FOR BEND LIMITING TUBE:</b> FOLLOW C 5 TO 7 & FINISH WITH STEP 12.	ABLE PRE	PERATION	STEPS
FOR 2.4mm OR 3.0mm DIAMETER PREPERATION STEPS 8 TO 12.	CABLE:	FOLLOW	CABLE

Copyright Prysmian Group - 2022 You may not copy, reprint, or reproduce in any form the content, either wholly or in part, of this Installation Guide, without the written permission of the copyright owner. Specifications are for product as supplied by Prysmian Group: any modification or alteration afterwards of product may give different result. The information is believed to be correct at the time of issue. Prysmian Group reserves the right to amend the information within this Installation Guide without prior notice. This Installation Guide may include inaccuracies, omissions of content and of information and is not contractually valid unless specifically authorised by Prysmian Group. Property of Prysmian Group UK - Uncontrolled when printed Prysmian Cables & Systems Limited, Chickenhall Lane, Eastleigh, Hampshire, SO50 6YU, United Kingdom.

PRYSMIAN HELPLINE: + 44 (0) 7816191633 connectivity.helpline@prysmiangroup.com

Page 17 of 17